

कार्यालय मुख्य चिकित्सा अधिकारी, वाराणसी।

सं०सी०एम०ओ०-3 / स्व०प्र०प० / 2026 /

दिनांक 20 फरवरी, 2026

प्रमाण-पत्र

प्रमाणित किया जाता है कि जागरण पब्लिक स्कूल, कृष्णा नगर, दरेखूं, जी०टी० रोड, वाराणसी के प्रधानाचार्य के पत्र दिनांक 28-01-2026 जो कि स्वच्छता प्रमाण पत्र जारी किये जाने से सम्बन्धित है। उक्त की जाँच इस स्तर से डा०राहुल सिंह, जिला कुष्ठ अधिकारी, वाराणसी से कराया गया। जाँच अधिकारी द्वारा प्रेषित जाँच आख्या दिनांक 12-02-2026 के क्रम में जागरण पब्लिक स्कूल, कृष्णा नगर, दरेखूं, जी०टी० रोड, वाराणसी स्वच्छता सम्बन्धी मानकों को पूरा किया जाना पाया गया।

मुख्य चिकित्सा अधिकारी,
वाराणसी।

सं०सी०एम०ओ०-3 / स्व०प्र०प० / 2026 / 1122-1

तददिनांक।

प्रतिलिपि प्रधानाचार्य, जागरण पब्लिक स्कूल, कृष्णा नगर, दरेखूं, जी०टी० रोड, वाराणसी को उनके प्रार्थना पत्र दिनांक 28-01-2026 के क्रम में सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।

मुख्य चिकित्सा अधिकारी,
मुख्य चिकित्सा अधिकारी
वाराणसी

Water Analysis Report

District Level Water Analysis Laboratory

(An NABL Accredited Lab)

Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005



Report No. C/VNS/SLP26/00063

Date: 21/09/2026

No. of Pages: 1

Customer Details

Office Name and Address

Jagran Public School Krishna Nagar, Darekhu, G.T. Road, Varanasi

Ref. Letter No. & Date

IPS/VNS/01

Date: 14/09/2026

Basic Details of Sample

District

Varanasi

Block

NA

Gram Panchayat

NA

Village

Darekhu

Habitation

NA

Location

School Campus

Water Source

B.O. Water

Sample Code

VNS/SLP26/0065

Quantity of Sample

1000 ml (Normal)

Sampling date

14/09/2026

Sample Received Date

15/09/2026

S. collected by

Mr Yogesh Kumar Pandey

Sampling Method Used

NA

Sample Depositor

Mr Yogesh Kumar Pandey

Analysis Start Date

19/09/2026

Analysis Completion date

19/09/2026

Temperature- 24.8°C, Humidity- 54%

Test Result

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	6.73	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	BDL (<0.5)	1	5	IS 3025 (Part 10): 2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	62.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	12.01	250	1000	IS 3025 (Part 32): 2025 (Argentometric method)
5	Total Alkalinity, (as CaCO ₃) mg/l	30.00	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	16.00	200	600	IS 3025 (Part 21): 2023 (EDTA method)
7	Calcium (as Ca), mg/l	BDL (<5)	75	200	IS 3025 (Part 40): 2024 (EDTA Titrimetric method)
8	Magnesium (as Mg), mg/l	BDL (<5)	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO ₄), mg/l	BDL (<1)	200	400	APHA 24rd Edition -4500-SO ₄ Method I (Turbidimetric Method): 2023
10	Nitrate (as NO ₃), mg/l	BDL (<0.2)	45	No relaxation	APHA 24rd Edition -4500-NO ₃ Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	0.10	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method): 2023
12	Iron (as Fe), mg/l	BDL (<0.1)	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method): 2023

BDL-Below Detection Limit, NA- Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.

3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.

4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.

5. Parameters above Permissible Limit are written in bold.

6. Sample is not collected by the Lab.

7. Source is not verified by the Lab.

ABHAY KUMAR PANDEY
(Report prepared by)

(Report Reviewed & Authenticated by)

Laboratory Contact detail:

Email: aroupjn@gmail.com

Mobile No.: 8400202287

*****END OF THE ANALYSIS REPORT*****

MANAGE
JAGRAN PUBLIC SCHOOL
VARANASI

Aaricetaa



Vinod Kumar
Vivekananda
21/09/2026

(Report Reviewed & Authenticated by)

Quality Manager